



**Williamsburg - James City County Public School Division
Invitation for Bid 14-6421
HVAC FILTERS**

DATE: April 30, 2014

ADDENDUM NO. 1

This Addendum is provided to answer bidder's questions. Please contact Jenise Howard, Jenise.Howard@jamescitycountyva.gov, if you have questions pertaining to this addendum.

The above referenced IFB is hereby amended and clarified as follows:

The following modifications, additions, and deletions are *hereby incorporated into the contract documents*.

QUESTIONS:

1. Can you provide additional specs about the box filters? Could you provide the manufacturer's name and model number of your current filter so we are certain to compare apples to apples?

Answer: The current filter is American Air Filter VariCel and VariCel with Antimicrobial, Merv 14 version.

2. Are the 1" odd sized filters Merv 8 pleated filters?

Answer: Yes. The 1" odd sizes are pleated.

3. Regarding the bid due date, will emailed or faxed responses be accepted?

Answer: No, please refer to the IFB documents (Section XII, Bid Submission Requirements).

4. If mailing the bid, will the postmark date matter, or will only the date received at your office be taken into consideration?

Answer: No, the postmark date holds no merit. All bids must be received in the Purchasing Office by the deadline on the IFB documents.

This Addendum 1 is incorporated into the Bid Documents and will be made part of the resulting contract. Please acknowledge receipt of this Addendum in the space provided in the proposal form section of the Invitation for Bid.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.